LIVERMORE
CALIFORNIA

Above Ground Tanks Containing Hazardous Materials

Portable and stationary tanks equal to or less than 120 gallons:

The Fire Code regulates these types of tanks. No Building Division review is required.

Stationary tanks of 121 gallons up to and including 500 gallons:

The Fire, Zoning, and Building Codes regulate these types of tanks. Permits are required and plans will be submitted to the Building Division and routed to Fire Prevention and Planning for their approvals.

A site plan, specifications on the tank, and structural drawings showing the method of support are required for the Building Division review. These drawings shall show the foundation system and method of preventing overturning. Engineered drawings and calculations are ***not*** required.

If the tank is pre-manufactured, no additional structural information is required on the tank.

Stationary tanks over 500 gallons:

The Fire, Zoning, and Building Codes regulate these types of tanks. Permits are required and plans will be submitted to the Building Division and routed to Fire Prevention and Planning for their approvals.

A site plan, specifications on the tank, and structural drawings showing the method of support are required for the Building Division review. These drawings shall show the foundation system and method of preventing overturning. These drawings ***are*** to be signed and sealed by an engineer, and calculations ***are*** to be provided.

If the tank is pre-manufactured, no additional structural information is required on the tank.

The Fire Prevention Bureau and Planning Divisions shall be contacted for tank installations that are not regulated by the Building Division.

City Hall
Permit Center

Community Development Department
1052 South Livermore Avenue
Livermore, CA 94550

phone: (925) 960-4410
fax: (925) 960-4419
TDD: (925) 960-4104

www.ci.livermore.ca.us